

QUICK REFERENCE DATA

RSA3ME4M Series Split System Air Conditioner for Manufactured Housing

14.3 SEER2

MODEL NUMBER: RSA3ME4M		1RN24K	1RN30K	1SN36K	1SN42K	1SN48K	1SN60K
RECOMMENDED REFRIGERANT SUCTION LINE O.D NOTE: Liquid line is 3/8" O.D. for entire length.	0 - 24 ft.	3/4"	3/4"	3/4"	7/8"	7/8"	7/8"
	25 - 39 ft.	3/4"	3/4"	7/8" (1)	7/8"	7/8"	7/8"
	40 - 75 ft.	3/4"	3/4"	7/8" (1)	7/8"	7/8"	7/8"
REFRIGERANT CHARGE R-410A in ounces for outdoor unit & 20' Lineset. (2)		68	74	69	84	83	95

(1) Requires 7/8" to 3/4" reducer from line to unit.

(2) Requires 1-1/8" to 7/8" reducer from line to unit

(3) Additional charge for line sets above 20 feet. Values based on suction line as follows with 3/8" liquid line.

(a) 3/4" = 0.6 oz. per additional foot.

(b) 7/8" = 0.7 oz. per additional foot.

(c) 1 1/8" = 0.8 oz. per additional foot.

*For other line set dimensions, refer to the Application Guidelines for Refrigerant Lines Addendum.

Table 1. Physical Data

MODEL NUMBER: RSA3ME4M		1RN24K	1RN30K	1SN36K	1SN42K	1SN48K	1SN60K
OUTDOOR UNIT BOM CHARGE (OZ.)		68	74	69	84	83	95
MODELS	SUPPLIED WITH ID	REQUIRED RESTRICTOR OR TXV (CHARGE ADDITION (OZ) / RATED AIRFLOW (SCFM))					
C84-X							
C84DAMX24U-B	669564	669564 (0 / 800)	--	--	--	--	--
C84DAMX30U-B	669565	--	669565 (0 / 1005)	--	--	--	--
C84DAMX36U-B	669566	--	--	669566 (0 / 1180)	--	--	--
C84DAMX42U-B	669567	--	--	--	669567 (0 / 1230)	--	--
C84DAMX48U-B	669568	--	--	--	--	669568 (0 / 1410)	--
C84DAMX60U-B	669578	--	--	--	--	--	669578 (0 / 1580)

NOTES:

- The charges listed are only valid for the standard 20' lineset.
- Numbers listed as 0.*** are restrictor diameters, while numbers listed as 669*** are TXV part numbers.

THE CHARGE ADDITIONS PROVIDED IN THIS DOCUMENT ARE ESTIMATES BASED ON TEST DATA AND SHOULD ONLY BE A STARTING POINT. AFTER FOLLOWING THESE DIRECTIONS PLEASE ADJUST THE REFRIGERANT AMOUNT BASED ON THE APPROPRIATE CHARGING TABLES OR CHARTS IN THE INSTALLATION INSTRUCTIONS OR CHARGING LABEL.

Instructions:

1. Find the column for the model of outdoor unit that is being installed.
2. Find the row for the model of the indoor unit that is being installed.
3. Find the cell in the table in which this row and column meet. In this cell the appropriate orifice / TXV and charge addition for this match are listed. If the text in this cell is BOLD, then a change of orifice is necessary.
4. If a change in restrictor is necessary, then the appropriate restrictor will already be supplied with the outdoor unit.

Examples:

- For the RSA3ME4M1RN24K / C84DAMX24U-B match the appropriate TXV is 669564 and no additional charge needs to be added. (NO CHANGES NECESSARY).
- For the RSA3ME4M1SN36K / C84DAMX36U-B match the appropriate TXV is 669566 and no additional charge needs to be added. (NO CHANGES NECESSARY).

Table 2. Restrictor or TXV / Charge Addition (Oz)

