INSTALLATION INSTRUCTIONS

WARNING:

ELECTRICAL SHOCK, FIRE OR EXPLOSION HAZARD

Failure to follow safety warnings exactly could result in serious injury or property damage. Improper servicing could result in dangerous operation, serious injury, death or property damage.

- Before servicing, disconnect all electrical power to air handler.
- When servicing controls, label all wires prior to disconnecting. Reconnect wires correctly.
- Verify proper operation after servicing.



The instructions listed below describe how to properly install the outdoor thermostat.

- 1.Connect one side of the wire (1) to a terminal on the Outdoor Thermostat (2).
- 2.Connect the terminal adapter (3) to the free terminal on the ODT (2).
- 3.Connect the free end of the wire (1) to the "W2" on the Defrost Board and the terminal (3) to the "E" on the Defrost Board.



Specifications & illustrations subject to change without notice or incurring obligations (07/15). O'Fallon, MO, © Nortek Global HVAC LLC 2015. All Rights Reserved.