QUICK REFERENCE DATA

DS4BD Series Residential Split System Air Conditioner

MODEL NUMBER: DS4BD-		018KB	024KB	030KB	036KB	042KB	048KB	060KB	
	Volts-Cycles Phase (1)		208 / 230 - 60 - 1						
Electrical Data	Total Amps		9.3	13.5	14.8	18.0	19.4	23.2	27.8
	Delay Fuse Max. (2)		20	25	30	35	40	50	60
	Min. Circuit Ampacity		11.6	16.7	18.3	22.2	23.9	28.7	34.4
	Coil	Area	8.3	8.3	10.0	10.0	15.3	15.3	17.9
		Rows-FPI	1-18						
		Tube Dia.	Micro-Channel						
Component	Fan Motor	Туре	PSC						
Data		Amps	0.35	0.7	0.7	1.4	1.5	1.5	1.5
		HP	0.05	0.1	0.1	0.25	0.25	0.25	0.25
	Compressor Data	RLA	9.0	12.8	14.1	16.6	17.9	21.8	26.4
		LRA	48.0	58.3	73.0	79.0	112.0	117.0	134.0
REFRIGERANT SUCTION LINE O.D NOTE: Liquid line is 3/8" O.D. for entire length. 40 - 75 ft.		3/4"	3/4"	3/4"	3/4"	7/8"	7/8"	7/8"	
		25 - 39 ft.	3/4"	3/4"	3/4"	7/8" (3)	7/8"	7/8"	1-1/8" <i>(4)</i>
		40 - 75 ft.	3/4"	3/4"	3/4"	7/8" (3)	7/8"	7/8"	1-1/8" (4)
REFRIGERANT CHARGE R-410A in ounces for outdoor unit & 15' Lineset. (5)		40.4	46.0	40.0	51.0	66.0	96.0	105.6	
APPROXIMATE WEIGHT (LBS.) Net Ship		109	125	138	140	179	179	188	
		Ship	114	130	144	146	187	187	197

- (1) Operating Voltage Range: 187v min. 253v max.
- (2) HACR Type Circuit Breakers may be used.
- (3) Requires 7/8" to 3/4" reducer from line to unit.
- (4) Requires 7/8" to 1-1/8" reducer from line to unit.
- (5) Additional charge for line sets above 15 feet. Values based on suction line as follows with 3/8" liquid line.
 - (a) 3/4" = 0.6 oz. per additional foot.
 - (b) 7/8" = 0.7 oz. per additional foot.
 - (c) $1 \frac{1}{8}$ " = 0.8 oz. per additional foot.

Table 1. Electrical Specifications & Physical Data




Figure 1. Clearance Requirements

Wire Gauge	Recommended Maximum Wire Length (FT) from Unit to Thermostat				
22	45				
20	70				
18	115				
16	180				

Table 2. Control Wiring (24V)




Table 3. Unit Dimensions

Instructions:

- 1. Find the column for the model of outdoor unit that is being installed.
- 2. Find the row for the model of the indoor unit that is being installed.
- 3. Find the cell in the table in which this row and column meet. In this cell the appropriate orifice /TXV and charge addition for this match are listed. If the text in this cell is BOLD, then a charge of orifice is necessary.
- 4. If a change in restrictor is necessary, then the appropriate restrictor will already be supplied with the outdoor unit.

Examples:

- For the DS4BD-030KB / C5(B,D)A-X30U-B match, the appropriate TXV is the 669565 and 36 ounces of charge will need to be added. (CHANGE IN CHARGE)
- For the DS4BD-024KB / C8(B,D)AM01830U-B match, the appropriate restrictor is the .055 and no additional charge needs to be added. (CHANGE IN RESTRICTOR)

	Model Number:	018KB	024KB	030KB	036KB	042KB	048KB	060KB		
	ID Restrictor Supplied	0.048	0.055							
	Outdoor Unit BOM Charge (Oz.)		40.4	46	40	51	66	96	105.6	
	MODELS SUPPLIED WITH ID		REQUIRED RESTRICTOR OR TXV / CHARGE ADDITION (OZ) / RATED AIRFLOW (SCFM)							
	C5									
Restrictor Installed With ID Unit	C5(Q,D)A-X25U-B	669564	669564 (30 / 525)	669564 (24 / 700)						
	C5(Q,D)A-X30U-B	669565			669565 (36 / 950)					
	C5(Q,D)A-X37U-B	669566				669566 (21 / 1100)				
	C5(Q,D)A-X42U-B	669567					669567 (27 / 1275)			
or In	C8									
ID Restrict	C8(B,D)AM01830U-B	0.061	0.048 (0 / 535)	0.055 (0 / 705)	0.061 (0 / 960)					
	C8(B,D)AM036U-B	0.067				0.067 (0 / 1190)				
	C8(B,D)AM042U-B	0.071	1		1		0.071 (0 / 1290)			
	CM4B									
	CM4B-53U	TXV	-1		-1		TXV (27 / 1300)			
	CM4B-54U	TXV						TXV (0 / 1300)	TXV (0 / 1400)	
	CM4B-56U	TXV						TXV (0 / 1400)	TXV (0 / 1600)	

NOTES:

- The charges listed are only valid for the standard 15' lineset.
- Numbers listed as 0.*** are restrictor diameters, while numbers listed as 669*** are TXV part numbers.

Table 4. Restrictor or TXV / Charge Addition (Oz)



